

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3774-1556:102

Page 1 of 1

CATEGORY: Electric Locks

LISTEE: Folger Adam Security Inc., 1902 Airport Rd., Monroe, NC 28110
Contact: Jeff Trull (704) 283-2101 FAX (704) 226-6198

DESIGN: Electric Strikes, Series 310 with suffix numbers $-\frac{1}{2}$ -1, -2, $2-\frac{3}{4}$ -3, -3-1, and -4. May include one or more of the following suffix letters: EL, LBM, LCM, LCBM, LCBMA, $\frac{3}{4}$ U, PK, DBR and DBS.

Electric Strikes, Series 600, Models 640, 642, 650, 652, 660, 662, 670, and 672. May include one or more of the following suffix letter: LBM, LCM, LCBDM, DBS, CYL, ARL, RFL and SYL, SYO, RFO and SSO, AC, LCMLBM, DKT.

Electric Strikes, Series 700, Models 710, 712, 712-75, 722, 730, 732, 732-75 and 775. May include one or more of the following suffix letter: LBM, LCM, SO, LCBM, LCMA, RF, and EL.

Each unit listed above is an assembly of solenoid, latching mechanisms, switches, and other mechanical parts secured inside of a metal enclosure, and provided with a metal faceplate. Refer to the listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as electronic strikes, which are intended for use on single swinging type fire doors measuring up to and including 48 inch wide and 96 inch high rated up to and including 3 hours. Authority having jurisdiction shall be consulted prior to installation. Refer to listee's Installation Instruction Manual for details.

07-10-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JULY 22, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager